



**SECTION**  
N.T.S.

**NOTES:** 1. FOR LONG LENGTHS OF SIDEWALKS, EXPANSION JOINTS (1/2" WIDTH, FULL DEPTH, WITH SEALANT) SHALL BE CONSTRUCTED EVERY 12 FEET AND CONTRACTION JOINTS (1/4" WIDTH, 1" DEEP WITH SEALANT) EVERY 4 FEET CENTER TO CENTER.

TYPICAL DETAILS		
<b><u>CONCRETE WALKWAY</u></b>		
THE EADS GROUP INC.	STD.	30